



ದೂರವಾಣಿ : 080 25570733  
22971501  
22971507

ಪೊಲೀಸ್ ಮಹಾ ನಿರ್ದೇಶಕರು  
ಹಾಗೂ ಮಹಾ ನಿರ್ದೇಶಕರು  
ಕರ್ನಾಟಕ ರಾಜ್ಯ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು  
ಸೇವೆಗಳು ಹಾಗೂ ರಾಜ್ಯ ವಿಪತ್ತು ಸ್ವಂದನಾ  
ಪಡೆಯ ನಿರ್ದೇಶನಾಲಯ  
ನಂ.1 ಅನ್ಯಾಸ್ಪಾನಿ ಮೊದಲಿಯಾರ್ ರಸ್ತೆ  
ಬೆಂಗಳೂರು-560 042  
ಸಂಖ್ಯೆ:ಜಿಬಿಸಿ(2)3425/2024  
E-Office Com No.49145

ದಿನಾಂಕ:06-03-20255

ಗೆ,

ಕಾರ್ಯಾಧಿಕಾರಿ,  
ಮೆ|| ಅಮೃತಾಯ ಟ್ರಸ್ಟ್  
ನಂ.37, ಮೊದಲನೇ ಮುಖ್ಯ ರಸ್ತೆ,  
ಆರ್.ಪಿಸಿ ಬಡಾವಣೆ,  
ಬೆಂಗಳೂರು-560040.

ಮಾನ್ಯರ,

ವಿಷಯ: ಬೆಂಗಳೂರು ಉತ್ತರ, ಜಾಲ ಹೋಬಳಿ, ಕಟ್ಟಿಗನಹಳ್ಳಿ,  
ನಂ.58/3 ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ ಮೇ|| ಅಮೃತಾಯ  
ಸೆಂಟ್ರಲ್ ಸ್ಕೂಲ್ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಸಮಾಪನ ಪತ್ರ  
ನೀಡುವ ಬಗ್ಗೆ.

ಉಲ್ಲೇಖ:1) ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯ ಸಲಹಾ  
ಪತ್ರ ಸಂ. ಜಿಬಿಸಿ(2)3425/2024 ದಿನಾಂಕ:24-01-2025.  
2) ನಿಮ್ಮ ಪತ್ರ ದಿನಾಂಕ:-28-01-2025.

<<<<<<>>>>>>>>

ಬೆಂಗಳೂರು ಉತ್ತರ, ಜಾಲ ಹೋಬಳಿ, ಕಟ್ಟಿಗನಹಳ್ಳಿ, ನಂ.58/3 ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ 20.00  
ಮೀಟರ್ ಎತ್ತರದ ನೆಲಹಂತ ಮತ್ತು 04 ಮೇಲಂತಸ್ತುಗಳನ್ನು ಹೊಂದಿರುವ ಮೇ|| ಅಮೃತಾಯ ಸೆಂಟ್ರಲ್  
ಸ್ಕೂಲ್ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯಿಂದ ದಿನಾಂಕ:24-01-2025  
ರಂದು ನಿಮ್ಮ ಕೋರಿಕೆಯಂತೆ ಸಲಹಾ ಪತ್ರ ನೀಡಲಾಗಿದೆ.

ಉಲ್ಲೇಖ (2)ರ ನಿಮ್ಮ ಪತ್ರದಲ್ಲಿ ಸದರಿ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡದಲ್ಲಿ ಅಗ್ನಿಶಾಮಕ ಉಪಕರಣಗಳ ಅವಶ್ಯಕ  
ಕಾರ್ಯ ಮುಗಿದಿದ್ದು, ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯ ಸಮಾಪನ ಪತ್ರ ನೀಡುವಂತೆ  
ಕೋರಿರುವಿರಿ.

ನಿಮ್ಮ ಕೋರಿಕೆಯಂತೆ, ಜಿಲ್ಲಾ ಅಗ್ನಿಶಾಮಕ ಅಧಿಕಾರಿ, ಪೀಣ್ಯ ಅಗ್ನಿಶಾಮಕ ಠಾಣೆ, ಕರ್ನಾಟಕ  
ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳ ರವರು ದಿನಾಂಕ:05-02-2025 ರಂದು ಬೆಂಗಳೂರು ಉತ್ತರ, ಜಾಲ  
ಹೋಬಳಿ, ಕಟ್ಟಿಗನಹಳ್ಳಿ, ನಂ.58/3 ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡವನ್ನು ಪರಿವೀಕ್ಷಣೆ ಮಾಡಿ, ಅಗ್ನಿಶಾಮಕ  
ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯು ನೀಡಿರುವ ಸಲಹಾ ಪತ್ರದಂತೆ, ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ನಿಯಂತ್ರಣ,  
ಅಗ್ನಿನಂದಿಸುವ ಉಪಕರಣಗಳ ಅವಶ್ಯಕ ಹಾಗೂ ರಕ್ಷಣಾ ಕ್ರಮಗಳನ್ನು ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡದಲ್ಲಿ ಪೂರ್ಣವಾಗಿ  
ಅನುಷ್ಠಾನಗೊಳಿಸಿರುವುದಾಗಿ ಹಾಗೂ ಸದರಿ ಕಟ್ಟಡದಲ್ಲಿನ ನೌಕರರು/ಸಿಬ್ಬಂದಿಗಳಿಗೆ ಅಗ್ನಿಶಾಮಕ ಕುರಿತ  
ತರಬೇತಿ ಮಾತ್ರ ಬಾಕಿ ಇರುವುದಾಗಿ ಹಾಗೂ ಸದರಿ ಕಟ್ಟಡದ ಸಮಾಪನ ಪತ್ರ ತರುವಾಯ ಅದರಲ್ಲಿನ  
ಸಿಬ್ಬಂದಿಗಳಿಗೆ ಅಗ್ನಿಶಾಮಕ ಕುರಿತ ತರಬೇತಿ ವ್ಯವಸ್ಥಿಸಲು ಸಾಧ್ಯವಾಗುತ್ತದೆಂದು ತಿಳಿಸಿರುತ್ತಾರೆ.

ಆದ್ದರಿಂದ, ಬೆಂಗಳೂರು ಉತ್ತರ, ಜಾಲ ಹೋಬಳಿ, ಕಟ್ಟಿಗನಹಳ್ಳಿ, ನಂ.58/3 ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ 20.00  
ಮೀಟರ್ ಎತ್ತರದ ನೆಲಹಂತ ಮತ್ತು 04 ಮೇಲಂತಸ್ತುಗಳನ್ನು ಹೊಂದಿರುವ ಮೇ|| ಅಮೃತಾಯ ಸೆಂಟ್ರಲ್

Kalyani  
Secretary

AMRUTHAYA CENTRAL SCHOOL  
Survey No.58/3, Kattigenahalli,  
Jala Hobli, Bangalore North-560064

Amrutha  
PRINCIPAL

AMRUTHAYA CENTRAL SCHOOL

ಸೂಲ್ ಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯ ಸಲಹಾ ಪತ್ರ ಸಂಖ್ಯೆ ಜೆಡಿಪಿ(2)3425/2024 ದಿನಾಂಕ:24-01-2025 ರಲ್ಲಿ ತಿಳಿಸಿರುವಂತೆ, ಅಗ್ನಿರಕ್ಷಣೆ ಮತ್ತು ನಿಯಂತ್ರಣ ಹಾಗೂ ಅಗ್ನಿನಂದಿಸುವ ಉಪಕರಣಗಳ ಅಳವಡಿಕೆ ಹಾಗೂ ರಕ್ಷಣಾ ಕ್ರಮಗಳನ್ನು ಕಟ್ಟುನಿಟ್ಟಾಗಿ ಪಾಲಿಸಬೇಕೆಂದು ಹಾಗೂ ನಿಮ್ಮ ದಿನಾಂಕ:25-02-2025 ರ ಮುಖ್ಯಳಿಕೆ ಪತ್ರದಲ್ಲಿ ಒಪ್ಪಿರುವಂತೆ, ಅಗ್ನಿಶಾಮಕ ಉಪಕರಣಗಳನ್ನು ಸುಸ್ತಿಯಲ್ಲಿಡಬೇಕೆಂಬ ಹಾಗೂ ಕಟ್ಟಡದಲ್ಲಿನ ಶೇಕಡಾ 40% ರಷ್ಟು ಸ್ಟ್ಯಾಂಡಿ/ನೋಕರಿಗೆ ಅಗ್ನಿರಕ್ಷಣೆ ಮತ್ತು ನಿಯಂತ್ರಣ ಕ್ರಮಗಳ ಬಗ್ಗೆ ಬೆಂಗಳೂರಿನ ಆರ್.ಎ.ಮುಂಡೂರ್ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳೆ ಅಕಾಡಮಿಯಲ್ಲಿ ಸೂಕ್ತ ತರಬೇತಿಯನ್ನು 03 ತಿಂಗಳೊಳಗೆ ಪಡೆಯಲು ವ್ಯವಸ್ಥಿಸಬೇಕೆಂಬ ಷರತ್ತಿನ ಮೇಲೆ ಸಮಾಪನ ವರದಿ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯಿಂದ ನೀಡಲಾಗಿದೆ.

ಈ ಸಮಾಪನ ಪ್ರಮಾಣ ಪತ್ರವು ಜಾರಿಯಾದ ದಿನಾಂಕದಿಂದ ಮುಂದಿನ ಎರಡು ವರ್ಷದವರೆಗೆ ಬಾಲ್ವಿಯಲ್ಲಿರುತ್ತದೆ. ತದನಂತರ ಈ ಸಮಾಪನ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ನವೀಕರಿಸುವಂತೆ ತಿಳಿಸಲಾಗಿದೆ.

ಹಾಗೆಯೇ ಒಂದು ವೇಳೆ ಯಾವುದೇ ಸಂದರ್ಭದಲ್ಲಿ ಇಲಾಖೆಯ ಶಿಫಾರಸಿನನ್ವಯ ಅಳವಡಿಸಿರುವ ಅಗ್ನಿನಿವಾರಣೆ ಹಾಗೂ ಅಗ್ನಿಶಾಮಕ ಉಪಕರಣಗಳು ಸುಸ್ತಿಯಲ್ಲಿರದೇ ಇರುವುದು ಕಂಡು ಬಂದರೆ ಅಥವಾ ರಕ್ಷಣಾ ಕ್ರಮಗಳನ್ನು ಕಟ್ಟುನಿಟ್ಟಾಗಿ ಪಾಲಿಸದಿದ್ದರೆ ಅಥವಾ ಕಾನೂನಿನನ್ವಯ ಸದರಿ ಕಟ್ಟಡದ ಸುತ್ತ ಬಿಟ್ಟಿರುವ ತೆರೆದ ಪ್ರದೇಶದಲ್ಲಿ ಯಾವುದೇ ಹೆಚ್ಚುವರಿ ರಚನೆಗಳನ್ನು ನಿರ್ಮಾಣ ಮಾಡಿದರೆ, ಅಥವಾ ಯಾವುದೇ ರೀತಿಯ ಖಾಯಂ/ತಾತ್ಕಾಲಿಕ ಅಡಚಣೆಗಳನ್ನು ಉಂಟು ಮಾಡಿದರೆ, ಈ 'ಸಮಾಪನ' ಪ್ರಮಾಣ ಪತ್ರವು ಅನುಷ್ಠಾನಗೊಳ್ಳುವುದು ಹಾಗೂ ಕಾನೂನಿನ ಚೌಕಟ್ಟಿನಲ್ಲಿ ಮುಂದಿನ ಕ್ರಮ ಕೈಗೊಳ್ಳಲಾಗುವುದು ಎಂಬುದಾಗಿ ಸೂಚಿಸಲಾಗಿದೆ.

ತಮ್ಮ ವಿಶ್ವಾಸಿ,

ಡಿಜಿಪಿ & ಡಿಜಿ ರವರಿಂದ

ಕರಡು ಅನುಮೋದಿಸಲ್ಪಟ್ಟಿದೆ

Digitally signed by  
T N SHIVASHANKARA  
Date: 06-03-2025  
18:21:38

(ಟಿ.ಎನ್.ಶಿವಶಂಕರ)

ನಿರ್ದೇಶಕರು

ಪೊಲೀಸ್ ಮಹಾ ನಿರ್ದೇಶಕರು

ಹಾಗೂ ಮಹಾ ನಿರ್ದೇಶಕರು

ಕರ್ನಾಟಕ ರಾಜ್ಯ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳು  
ರವರ ಪರವಾಗಿ

ಪ್ರತಿ:ಪ್ರಾದೇಶಿಕ ಅಗ್ನಿಶಾಮಕ ಅಧಿಕಾರಿ, ಬೆಂಗಳೂರು ಉತ್ತರ ವಲಯ.

Kalyani . K

Secretary

AMRUTHAYA CENTRAL SCHOOL

Survey No.58/3, Kattigenahalli,

Jala Hobli, Bangalore North-560064

Stamuntha B

PRINCIPAL

AMRUTHAYA CENTRAL SCHOOL

**GOVERNMENT OF KARNATAKA**

Director General of Police and Director General,  
Department of Fire and Emergency Services  
& State Disaster Response Force  
No.1, Annaswamy Modaliyar Road,  
Bangalore - 560042  
No: GBC(2) 3425/2024  
E-office Com No.: 49145

Phone: 080 25570733  
22971501  
22971507

Date: 06-03-2025

To:  
Secretary,  
M/s. Amruthaya Trust,  
No. 37, 1<sup>st</sup> Main Road,  
RPC Layout,  
Bangalore - 560040.

Respected Sir,

**Subject:** Regarding issuance of completion certificate of M/s. Amruthaya Central School situated at No.58/3, Kattigenahalli, Jala Hobli, Bangalore North.

**Reference:** 1. Fire and Emergency Services Department Advisory Letter No. GBC (2) 3425/2024, dt: 24.01.2025.  
2. Your letter dated: 28-01-2025.

An advisory letter has been issued by the Fire and Emergency Services Department on 24-01-2025 as per your request for the M/s. Amrutaya Central School educational building constructed at Kattiginahalli No.58/3, Jala Hobli, Bangalore North, with a ground floor height of 20.00 meters and 04 upper floors.

In your letter of reference (2), you have requested that the installation of fire extinguishing equipment in the said educational building has been completed and that a completion certificate be issued by the Fire and Emergency Services Department.

As per your request, the District Fire Officer, Peenya Fire Station, Karnataka Fire and Emergency Services inspected the educational building constructed at No. 58/3, Kattiginehalli, Jala Hobli, Bangalore North on 05-02-2025 and stated that as per the advisory letter issued by the Fire and Emergency Services Department, fire protection and control, installation of fire extinguishing equipment and safety measures have been fully implemented in the educational building and that only fire training is pending for the employees/staff in the said building and after the completion letter of the said building, it will be possible to arrange fire training for the staff in it.

*Kalyan K.*  
Secretary

**AMRUTHAYA CENTRAL SCHOOL**  
Survey No.58/3, Kattigenahalli,  
Jala Hobli, Bangalore North-560064

*Amruthaya*  
PRINCIPAL

**AMRUTHAYA CENTRAL SCHOOL**



Therefore, the building constructed at M/s. Amrutaya Central School, Kattiginahalli No.58/3, Jala Hobli, Bangalore North, with a ground floor height of 20.00 meters and 04 upper floors, the Educational Building Fire and Emergency Services Department Advisory Letter No. GBC (2) 3425/2024, dt: 24-01-2025, Fire extinguishing equipment and safety measures shall be strictly followed and as agreed in your letter of undertaking dated 25-02-2025, fire extinguishing equipment shall be kept in good condition and arrangements shall be made for 40% of the staff/employees in the building to undergo appropriate training on fire protection and control measures at R.A. Mundur Fire and Emergency Services Academy, Bangalore within 03 months.

This Completion Certificate shall be valid for the next two years from the date of issue. It has been further advised to renew this completion certificate.

It has also been advised that if at any time the fire protection and fire extinguishing equipment installed as per the department's recommendation is found to be not in good condition or the safety measures are not strictly followed or any additional structures are constructed in the open area left by law around the said building or any kind of permanent/temporary obstruction is caused, this 'completion' certificate will be void and further action will be taken within the framework of the law.

Draft approved by DGP & DG

Yours faithfully,  
Digitally Signed by:  
T N SHIVASHANKARA  
Date: 06-03-2025  
18:21:38

(T.N. Shivashankara)  
Director  
On behalf of the Director General of Police  
and the Director General of  
Karnataka State Fire and  
Emergency Services

Copy to: Regional Fire Officer, Bangalore North Zone.

*Kalyani K.*  
Secretary

AMRUTHAYA CENTRAL SCHOOL  
Survey No.58/3, Kattigenahalli,  
Jala Hobli, Bangalore North

TRANSLATION ATTESTED BY ME

DEEPA. M., B.A.L.,LL.B.,  
ADVOCATE & NOTARY PUBLIC  
GOVT OF INDIA

*Amrutha B*  
PRINCIPAL  
AMRUTHAYA CENTRAL SCHOOL

